

**Office of the Joint Director Fire & Emergency Services  
Jammu Range, Jammu**

**The Principal  
Police Public School  
Miran Sahib, R.S.Pura**

No: JDJF&ES/FP/ 304

Dated: 15.01.2021

**Sub:** Provisional Fire Safety Certificate.

**Ref:** Your Letter No.PPSJ/06/2020/4932-34 dated: 22.12.2020.

**Dear Sir,**

The spot inspection of the above noted School has been got carried out by the inspecting officer of this department. The detailed report of which is as under:-

**LOCATION / ACCESSIBILITY:**

The school building is situated at Miran Sahib, R.S.Pura, Jammu. The site is about 04 km away from Fire & Emergency Station R.S.Pura Jammu and is approachable for fire tenders in case of any emergency.

**DETAIL OF BUILDING:**

The school comprises 04 Blocks, in which two double storied and two are triple storied. Out of two triple storey blocks one is having basement.

**EXISTING FIRE FIGHTING SYSTEM:**

At present First Aid Fire Extinguishers of different type and capacities are installed in the school premises, but maximum Fire Extinguishers are needs refilling/replacement.

Presently there is one underground water storage tank of 60 KL capacity is available near main block in the school premises.

**FIRST AID FIRE FIGHTING SYSTEM FOR IMPLEMENTATION-ESSENTIAL REQUIREMENT:**

- I) For triple storied blocks, Hose Reel Hoses as per BIS specifications connected with the terrace tank of 5000 Ltrs. capacity should be provided in the School. The Hose Reel Hose should be kept at such a place where from every nook and corner of each floor of each triple storied building are covered easily at the time of any emergency. A Fire Pump of desired capacity should be installed near underground water storage tank with dual electric supply for feeding the terrace tank.
- II) Automatic Sprinklers system should be provided in the basement of main block.
- III) Adequate numbers of First Aid Fire Extinguishers should be installed at appropriate locations of each block.
- IV) All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency
- V) No Hazardous material should be kept inside the School premises (especially **LPG cylinder, Petrol and Diesel** etc.).
- VI) All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
- VII) The corridor of the building shall not be used for any kind of storage.
- VIII) One window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
- IX) Telephone numbers of nearest Fire & Emergency Stations should be displayed.
- X) Fire fighting system installed in the School building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the School building.
- XI) The management of the School shall be wholly and solely responsible for keeping the fire fighting system of the School in working condition 24x7 to face any eventuality.

**The management can proceed ahead for operation provisionally subject to implementation of above said recommendations in letter and spirit forthwith and report this office accordingly for issuance of Final Fire Safety Certificate. The validity of this letter shall remain in force for one year only.**

Yours Sincerely



**Joint Director**

**Fire & Emergency Services**

**Jammu Range, Jammu**

*Send to SO Section  
for further course of Action  
Renu - 16/1/21*